



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Oct 30, 2023

Inspection Result: NOT READY

Permit Number: PRCTI20230973

Property Address: 402 VALLEY AVE NW, Unit: A, PUYALLUP, WA 98371;

Contractor: RAFN COMPANY 1721 132ND AVE NE BELLEVUE, WA 98005--2250
(425) 702-6600

To construct: Build out of existing space for semi-heated warehouse with fully conditioned office and restroom space. CITC SOUTH PUYALLUP

On this day we have inspected your construction for **Plumbing Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

1. provide cane guard at drinking fountain
2. insulate and secure water lines at bath sinks as discussed with contractor

Sincerely,

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590