



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Nov 16, 2023 **Inspection Result:** **NOT READY**

Permit Number: PRCTI20230973

Property Address: 402 VALLEY AVE NW, Unit: A, PUYALLUP, WA 98371;

Contractor: RAFN COMPANY 1721 132ND AVE NE BELLEVUE, WA 98005--2250
(425) 702-6600

To construct: Build out of existing space for semi-heated warehouse with fully conditioned office and restroom space. CITC SOUTH PUYALLUP

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

1. provide engineering final approval prior to next inspection
2. provide clarification from architect on door hardware and exit signage at doors going into warehouse as discussed with contractor

Sincerely,

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590