



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Dec 05, 2023                      **Inspection Result:**      **PARTIAL PASS**

**Permit Number:** PRCCP20221569

**Property Address:** 4002 10TH ST SE, PUYALLUP, WA 98374;

**Contractor:** BRC FAMILY LLC PO BOX 731310 PUYALLUP, WA 98373-0060 GREAT  
NORTHWEST EXCAVATION LLC 12203 40TH AVE TACOMA, WA 98466

**To construct:** Extend utilities from 10th street SE on a site for purposes of construction  
2- 6 plexus as well as provide infiltration on site. COPPERBERRY  
CONDOMINIUMS

On this day we have inspected your construction for **Erosion And Sediment Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** Straw has been installed on the bare soil. Lumber moved from gutter pan, and nails picked up.

There is nothing leaving the site.

- No site run off.
- No track out.

Note: I text Scott to clean the CB sock on 10th north end of the project.

**Corrections:**

- 1 - Delineate west side of north building. This area is soft. No fork lift and minimal foot traffic.
  - Maintain frontage cleanliness. (Gutter pan, road way, sidewalk, etc...)
  - Maintain construction entrance. (Cleanliness, track out, etc...)
  - Watch runoff during heavy rain events.

Sincerely,



City of Puyallup

---

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

A handwritten signature in black ink, consisting of a large, loopy initial 'J' followed by several vertical, wavy lines that resemble the letters 'LITTLE'. A horizontal line extends from the right side of the signature.

Jason Little

Engineering Tech IV

[JLittle@PuyallupWA.gov](mailto:JLittle@PuyallupWA.gov)

(253) 435-3636