



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Apr 02, 2024

**Inspection Result:** PARTIAL PASS

**Permit Number:** PRCTI20231318

**Property Address:** 813 21ST ST SE, PUYALLUP, WA 98372;

**Contractor:** ABSHER CONSTRUCTION CO PO BOX 280 PUYALLUP, WA 98371-0152

**To construct:** Cascade Christian School - Jr. High School 2nd floor tenant improvement

On this day we have inspected your construction for **Plumbing Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** 1 ; approved water supply test,provide 10' head test at d.w.v. as discussed with contractor at 2nd floor restrooms.

**Corrections:**

Sincerely,

Shannon King  
Building Inspector 2  
ShannonK@PuyallupWA.gov  
(253) 840-6684