



CITY OF PUYALLUP
Development & Permitting Services
 333 S. Meridian, Puyallup, WA 98371
 (253) 864-4165
www.cityofpuyallup.org

Permit No:
 PRFS20240441

FIRE SPRINKLERS
 Puyallup, WA

Job Address	Address: 815 21ST ST SE, PUYALLUP, WA 98372 Parcel # 0420352148	ISSUED April 08, 2024
Owner	CASCADE CHRISTIAN SCHOOLS 815 21ST ST SE PUYALLUP, WA 98372-4760	
Applicant	Luke Thompson 111 S Findlay St, Seattle, WA 98108 (206) 232-8569 luke@columbiafire.net	
Contractor	COLUMBIA FIRE INC 111 S FINDLAY ST SEATTLE, WA 98108 WA L&I #:	
Description of Work	NFPA 13 - 39 New Drop Pendant to the new grid Ceiling, Sprinkler Head match existing hydraulic calculations - CCS JR. HIGH, 2ND FLOOR	
Permit Types	Fire Sprinklers	
Expiration Date:	October 05, 2024	
Total ESU's		

Building Components:

Quantity	Units	Description
39	HEADS	Automatic Fire-Sprinkler System, Alteration
		Total Value of Work: \$0.00

Standard Conditions:

- Provide plans and permit on site for inspection.
 - Cover and final inspections are required.
 - Fire watch is required when sprinkler system is out of service in existing buildings.
 - Contractor required at all inspections.
 - Hydro test will be required on all new and existing buildings. Appointment required.
 - Hydro test, two inspections will be required 2hrs apart. Call to schedule times. Am/pm is not guaranteed without appointment.
 - Fire pumps will be required to be tested and witnessed by inspector.
 - Tool kit required at time of final.
 - NFPA placards required.
 - In existing buildings all upright fire sprinklers to remain, do not remove.
 - In existing buildings all required service and maintenance to be updated prior to inspection.

- Due to unforeseeable construction design, all head locations to be field verified for compliance. Schedule your inspection online through the city of puyallup online permit system. This is a request for inspection only. A date and time will be selected by Inspector depending on availability. Email morning of inspection between 7am – 8am for scheduled date and time. Fire Inspections are Monday – Thursday there will be no inspections on Fridays. For larger system please make an appointment prior to scheduling first.
David Drake ddrake@puyallupwa.gov

Permit is valid 180 days from date of issuance. Permit validity is subject to all adhering to all applicable codes, ordinances and standards, and conditions of this permit.

I certify that I am the owner of this property or the owner's authorized agent, including an appropriately licensed contractor. I have read and examined this application and furnished true and correct information. I will comply with all provisions of law and ordinances governing this type of construction work, whether specific herein or not. By submitting this application, I give the jurisdiction permission to enter the property to perform inspections. The granting of this permit does not presume or give authority to violate or cancel the provisions of any other state or local law regulating construction or the performance of construction. I understand that failure to comply with the above may result in revocation of the permit.

Applicant:
Luke Thompson