



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Apr 11, 2024

**Inspection Result:** **FAILED**

**Permit Number:** PRCTI20231318

**Property Address:** 813 21ST ST SE, PUYALLUP, WA 98372;

**Contractor:** ABSHER CONSTRUCTION CO PO BOX 280 PUYALLUP, WA 98371-0152

**To construct:** Cascade Christian School - Jr. High School 2nd floor tenant improvement

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 2 1 ; complete exit sign at top of stairs as per city approved plans at s.w. stairwell of 2nd floor.
- 2 ; complete nail plates at electrical penetration at south wall.
- 3 ; complete draftstop at 10' o.c. at south wall as marked on floor with paint per contractor,south wall of restroom,and center wall of restroom.
- 4 ; remove abandoned vent of d.w.v. in restroom.  
ok to insulate

Sincerely,

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)