



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: May 16, 2024

Inspection Result: NOT READY

Permit Number: PRCTI20230139

Property Address: 212 S MERIDIAN, PUYALLUP, WA 98371;

Contractor: CEDAR + SLATE HOME SERVICE LLC 17515 SR 302 NW GIG HARBOUR, WA 98329 (253) 271-3384

To construct: Construct a new cat cafe within the existing shell of the building.-
CATFFEINATED CAFE

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1. provide test on DWV at time of next inspection
- 2.complete positive attachment at all single top plates as discussed with contractor
- 3.complete all fire stop as discussed with contractor
4. provide fastener and plates at bottom plates per city approved plans
5. complete hangers at rafters in entry as discussed with contractor
- 6.complete duct seal
7. remove insulation from mechanical in attic to verify sealing of ducts
- 8.complete all seismic bracing on duct work
- 9.not a complete list

Sincerely,

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org