



C
christian
fynboe DE

CONSULTING ENGINEER

12181 C Street S. • TACOMA, WA 98444 • (253) 537-8128 • FAX 531-1285

PROJECT: TOYOTA OF PUYALLUP		SHEET NO. 1/1
BY: CF	DATE: 5/2/24	JOB NO. 24002

FULL SIZED LEDGIBLE COLOR REPORT IS
REQUIRED TO BE PROVIDED BY THE
PERMITTEE ON SITE FOR ALL INPECTIONS



REVISION

TO: CITY OF PUYALLUP BLDG DEPT
RE: TOYOTA OF PUYALLUP CANTOPY

THE CONCRETE FOR THE TWO HSS
COLUMNS ONLY NEEDS TO BE 2500PSI -
28 DAY STRENGTH, THEREFORE NO
SPECIAL INSPECTION IS REQUIRED.

