



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jun 05, 2024

Inspection Result: PASSED

Permit Number: PRCTI20230139

Property Address: 212 S MERIDIAN, PUYALLUP, WA 98371;

Contractor: CEDAR + SLATE HOME SERVICE LLC 17515 SR 302 NW GIG HARBOUR,
WA 98329 (253) 271-3384

To construct: Construct a new cat cafe within the existing shell of the building.-
CATFFEINATED CAFE

On this day we have inspected your construction for **Wallboard / Drywall Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

Sincerely,

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590