



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jun 10, 2024

Inspection Result: **FAILED**

Permit Number: PRFUP20240114

Property Address: 1601 3RD ST SE, PUYALLUP, WA 98372;

Contractor: NORTH SKY - CENTURY LINK 11818 SE MILL PLAIN BLVD VANCOUVER, WA 98684

To construct: Transfer CenturyLink services from old utility pole to new foreign pole already in place; previously issued permit #PRFUP20231007.

On this day we have inspected your construction for **Job Start Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Per North Sky, this work was errantly completed on 6/7 without a job start. Per inspection of 6/10, the following corrections are to be completed prior to permit closure:

CORRECTIONS:

Remove native backfill material at the riser and poles (disturbed area) and replace with import per City Standard Detail 06.01.01 - "Pipe Trenching Bedding and Backfill". Include the void at the back of the new pole. Compact with a mechanical compaction device.

Corrections:

Sincerely,

Cheryl Trimble

Engineer Tech II

CTrimble@PuyallupWA.gov



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

(253) 841-5464