



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jul 16, 2024

Inspection Result: PARTIAL PASS

Permit Number: PRCTI20230139

Property Address: 212 S MERIDIAN, PUYALLUP, WA 98371;

Contractor: CEDAR + SLATE HOME SERVICE LLC 17515 SR 302 NW GIG HARBOUR, WA 98329 (253) 271-3384

To construct: Construct a new cat cafe within the existing shell of the building.-
CATFFEINATED CAFE

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 date of inspection 7/13/2024
 - 1.seal line set house on roof
 - 2.label equipment on roof for space it is servicing
 - 3.remove debri from roof
 - 4.provide access,service platform, service plug and light at duct heater in attic per mech code
 - 5.provide plumbing boots at supply in storage room
 - 6.provide and maintain clear access at corridor where bathrooms are
 - 7.seal penetration's at mini split drain line
 - 8.do not use ice maker untel air gap is verified or RPBA is installed and certified
 - 9.see email from building official on back corridor future access
 10. provide permanent roof access as discussed with contractor
 11. pay after hours inspection fee for todays inspection prior to scheduling next inspection
 - 12.TCO granted for 10 working days
 - 13.all ceiling corrections approved

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590