



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Aug 08, 2024                      **Inspection Result:**     **PARTIAL PASS**

**Permit Number:** PRCA20240398

**Property Address:** 322 VALLEY AVE NW, PUYALLUP, WA 98371;

**Contractor:** THE WHITING-TURNER CONTRACTING COMPANY 300 EAST JOPPA ROAD , 8TH FLOOR BALTIMORE, MD 21286

**To construct:** 43,000 SF EXPANSION OF EXISTING FREEZER WAREHOUSE FACILITY - COASTAL PACIFIC FOOD DISTRIBUTORS

On this day we have inspected your construction for **Foundation/Rebar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 1. provide geo tech reports and special inspection reports for rebar on site at time of next inspection
- 2 date of inspection 8/6/2024
  1. provide special inspection report for rebar epoxied in to existing footing
  2. 1st phase of mech shaft approved per special inspection
  3. ok to pour as discussed with contractor
- 3 date of inspection 8/8/2024
  1. HVAC shaft walls approved to pour per special inspection

Sincerely,

Kevin Spruell  
Building Inspector  
KSpruell@PuyallupWA.gov  
(253) 841-5590



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)