



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Aug 30, 2024                      **Inspection Result:**      **PARTIAL PASS**

**Permit Number:** PRCNC20240216

**Property Address:** 325 TODD RD NW, PUYALLUP, WA 98371;

**Contractor:** PENNON CONSTRUCTION CO. INC. 9750 3RD AVE NE SEATTLE, WA 98115

**To construct:** THE PROPOSED PROJECT IS FOR A NEW OPERATIONAL TRAINING CENTER. THE PROJECT IS COMPOSED OF THE MAIN OTC BUILDING, AND OUTDOOR TRAINING AREA. IT WILL BE USED AS A VOCATIONAL SCHOOL FOR UTILITY FIRST RESPONDERS AND CONSTRUCTION TRADES. THE OTC BUILDING WILL CONSIST OF OFFICE/COMMERCIAL/INSTRUCTIONAL SPACES, AND COVERED AREA. THE OUTDOOR TRAINING AREA WILL CONSIST OF MULTIPLE ENCLOSED SINGLE STORY STRUCTURES.

On this day we have inspected your construction for **Footing/Setback Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 2 date of inspection 8/29/2024
  1. provide letter from EOR with comments regarding pipes running thru footing
  2. footings approved per special inspection as marked up on city approved plans pages S.202 and S.201

Sincerely,

Kevin Spruell  
Building Inspector



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

[KSpruell@PuyallupWA.gov](mailto:KSpruell@PuyallupWA.gov)

(253) 841-5590