



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

# Permit Review Correction Letter

## Permit Application #PRCA20240398 – 9/5 REVISION (2) - WATER STORAGE TANK

September 20, 2024

The City has completed the review of the above-mentioned permit REVISION submittal. All your review comments, conditions, and redlined plans can be found on the [City's permit portal](#). Redlined plans can be found on the City's Permit Portal in the "Reviews" section under "Documents Returned for Corrections". Below please find the permit submittal review comments from your review team and re-submittal instructions. Should you have any questions regarding the review comments, please contact the plan reviewer associated with the comment listed below.

### Re-submittal Instructions

To resubmit, you must address all comments and email a ~~Correction Response Letter~~ that states how the corrections have been addressed in your resubmitted documents along with a new plan set to [permitcenter@puyallupwa.gov](mailto:permitcenter@puyallupwa.gov). Be sure to include "RESUBMITTAL FOR REVISION (2) PERMIT PRCA20240398" in the subject line of your email. In addition, a resubmittal fee has been assessed and will need to be paid for the re-review of your revision – this can be paid at the time you send your email.

### Corrections

Corrections to be addressed on the next set of resubmitted plans:

<b>Building Review</b>	<b>Brian Snowden</b>	<b>(253)435-3618</b>	<b>BSnowden@puyallupwa.gov</b>
- Please have the engineer of record verify whether Special Inspection is required for the 4,000PSI concrete slab per Chapter 17 of the Washington State Building Code. If a Special Inspection is required for this, or any item, please include a Special Inspection statement on the plan set with a Special Inspection schedule. [Reference the marked-up document: FOUNDATION DETAIL - Ring Beam Detail AS-101]			

If you need assistance with resubmitting your corrections, please contact the Permit Center.

Sincerely,

City of Puyallup Permit Center

(253) 864-4165 option 1

[permitcenter@puyallupwa.gov](mailto:permitcenter@puyallupwa.gov)