



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Sep 20, 2024                      **Inspection Result:**     **FAILED**

**Permit Number:** PRCCP20240215

**Property Address:** 325 TODD RD NW, PUYALLUP, WA 98371;

**Contractor:** PENNON CONSTRUCTION CO. INC. 9750 3RD AVE NE SEATTLE, WA 98115 Sean Ewing 9750 3rd Ave NE, Ste 250, Pennon Construction Seattle, WA 98115 (206) 430-2537

**To construct:** THE PROPOSED PROJECT IS FOR A NEW OPERATIONAL TRAINING CENTER. The project is composed of the main OTC building, and Outdoor Training area. It will be used as a vocational school for UTILITY FIRST RESPONDERS AND construction trades.

On this day we have inspected your construction for **Erosion And Sediment Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** Silt fence need repair.

Outlet protection is needed where the storm line daylights west of 4th.  
check dams need to be installed per page C2.1.

The storm line in the ROW of Todd RD has been tied into the existing line. In a rain event water will be carried to the ditch west of 4th.

**Corrections:**

- 1 1- repair all damaged and removed silt fence
- 2- install check dams and outlet protection

Sincerely,

Jeff Hill  
Development Engineering Inspector  
Jhill@PuyallupWA.gov



City of Puyallup

---

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

(253) 204-5633