



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Sep 24, 2024 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRCA20240398

Property Address: 322 VALLEY AVE NW, PUYALLUP, WA 98371;

Contractor: THE WHITING-TURNER CONTRACTING COMPANY 300 EAST JOPPA ROAD , 8TH FLOOR BALTIMORE, MD 21286

To construct: 43,000 SF EXPANSION OF EXISTING FREEZER WAREHOUSE FACILITY - COASTAL PACIFIC FOOD DISTRIBUTORS - 9/4 REVISION (1) - MECHANICAL/PLUMBING SPECS (NOT ORIGINALLY PROVIDED) - 9/5 REVISION (2) - WATER STORAGE TANK

On this day we have inspected your construction for **Foundation/Rebar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1. provide geo tech reports and special inspection reports for rebar on site at time of next inspection
- 2 date of inspection 8/6/2024
 - 1.provide special inspection report for rebar epoxied in to existing footing
 2. 1st phase of mech shaft approved per special inspection
 3. ok to pour as discussed with contractor
- 3 date of inspection 8/8/2024
 - 1.HVAC shaft walls approved to pour per special inspection
- 4 date of inspection 8/14/2024
 - 1.HVAC lid approved per special inspection ok to pour
- 5 date of inspection 9/24/2024
 - 1.foundation walls at trash shoot area approved per special inspection as marked up on city approved plans PG S-101



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Sincerely,

Kevin Spruell
Building Inspector
KSpruell@PuyallupWA.gov
(253) 841-5590