



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Oct 01, 2024 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRCNC20240216

Property Address: 325 TODD RD NW, PUYALLUP, WA 98371;

Contractor: PENNON CONSTRUCTION CO. INC. 9750 3RD AVE NE SEATTLE, WA 98115

To construct: THE PROPOSED PROJECT IS FOR A NEW OPERATIONAL TRAINING CENTER. THE PROJECT IS COMPOSED OF THE MAIN OTC BUILDING, AND OUTDOOR TRAINING AREA. IT WILL BE USED AS A VOCATIONAL SCHOOL FOR UTILITY FIRST RESPONDERS AND CONSTRUCTION TRADES. THE OTC BUILDING WILL CONSIST OF OFFICE/COMMERCIAL/INSTRUCTIONAL SPACES, AND COVERED AREA. THE OUTDOOR TRAINING AREA WILL CONSIST OF MULTIPLE ENCLOSED SINGLE STORY STRUCTURES.

On this day we have inspected your construction for **Plumbing Below Slab Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 date of inspection 8/30/2024
 1. under slab DWV approved as marked up on city approved plans pages P1.01C and P1.01D
- 2 date of inspection 9/6/2024
 1. DWV under slab approved as marked up on city approved plans pages P1.01A , P1.01C , P1.01D
- 3 date of inspection 9/17/2024
 1. below slab plumbing approved as marked up on city approved plans pgs P1.01A and P1.01D
- 4 date of inspection 10/1/2024
 1. supply approved at 100 psi as marked up on city approved plans PG P1.01.D
 2. fix leaks on DWV at trench drain and retest as discussed with contractor



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Sincerely,

Kevin Spruell
Building Inspector
KSpruell@PuyallupWA.gov
(253) 841-5590