



City of Puyallup

Fire Prevention

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Permit Review Correction Letter

Permit Application #PRFA20241553

October 22, 2024

The City has completed the review of the above-mentioned permit submittal. All your review comments, conditions, and redlined plans can be found on the [City's permit portal](#). Redlined plans can be found on the City's Permit Portal in the "Reviews" section under "Documents Returned for Corrections". Below please find the permit submittal review comments from your review team and re-submittal instructions. Should you have any questions regarding the review comments, please contact the plan reviewer associated with the comment listed below.

Re-submittal Instructions

To resubmit, you must address all comments and upload a ~~Correction Response Letter~~ that states how the corrections have been addressed in your resubmitted documents. Avoid using "upload additional docs" unless there is NO submittal item available for your document. Please Note: If you have any questions about how to resubmit, please contact the permit center.

- 1 Log in to your permits portal and navigate to the status page for this permit under the "My Items" tab by selecting the "Upload Submittals" button under the permit number.
- 2 For each submittal item listed re-submit a new version of the submittal item by clicking the "New Version" button next to the file name of the original file submitted. DO NOT click the 'browse' button unless the document you are submitting for that submittal item is not a new version of the originally submitted document. Click 'Upload Documents' at bottom of the page.
- 3 If any re-submittal fees have been assessed, you will need to pay your resubmittal fee at the time of resubmittal. Your resubmittal will not be processed until the fee has been paid.

Corrections

Corrections to be addressed on the next set of resubmitted plans:

Fire Review	David Drake	(253)864-4171	DDrake@PuyallupWA.gov
<p>- I do not see that your company is U.L. listed? This is a requirement under our City Municipal Code. 17.16.020 Installation approval.</p> <p>Upon final inspection of all fire alarm systems, the installer shall provide the inspector evidence that the installer holds the required valid Washington State low voltage specialty electrical contractor’s license. Application for an Underwriters Laboratory Fire Alarm Certificate or other approved third-party verification service (to be determined by the fire code official) must be completed by an approved alarm service company and accepted by Underwriters Laboratory or other approved third-party verification service to final acceptance of the fire code official. The Underwriters Laboratory Fire Alarm Certificate or other approved third-party verification certificate shall not be cancelled or allowed to expire without the approval of the fire code official or his designee. Third party certification shall include qualifications review of installation, maintenance, and monitoring. Records of current certification shall be maintained at the fire alarm central panel. (Ord. 2801 § 6, 2004).</p> <p>- Plans do not meet our City Municipal Code Total Coverage NFPA 72.</p> <p>17.5.3.1 Total (Complete) Coverage. Where required by other governing laws, codes, or standards, and unless otherwise modified by 17.5.3.1.1 through 17.5.3.1.5, total coverage shall include all rooms, halls, storage areas, basements, attics, lofts, spaces above suspended ceilings, and other subdivisions and accessible spaces, as well as the inside of all closets, elevator shafts, enclosed stairways, dumbwaiter shafts, and chutes.</p>			

Conditions

The items listed in the table below are conditions of the permit that do not need to be addressed on the next resubmittal of plans but will need to be fulfilled at some point in the permit review process. The “Condition Category” indicates the approximate phase of the permit process by which the condition must be fulfilled for the City to continue processing this permit. “Condition Status” if “Open” means that the condition has not been fulfilled, if “Resolved” means the condition has been fulfilled successfully. For some conditions that require submittal of a document to the City, those documents can be submitted via the Conditions Section of the [City’s permit portal](#).

Condition Category	Condition	Department	Condition Status
---------------------------	------------------	-------------------	-------------------------

If you need assistance with resubmitting your corrections, please contact the Permit Center.

Sincerely,

City of Puyallup Permit Center
(253) 864-4165 option 1
permitcenter@puyallupwa.gov