



City of Puyallup

Fire Prevention

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Mark Smith - Smith Fire Systems

1106 54TH AVE EAST

TACOMA, WA 98424

December 02, 2024

Notice of Incomplete Permit Submittal

RE: Application Number PRFA20241832

Dear Mark Smith - Smith Fire Systems,

A permit application has been received by this office on November 27, 2024. The following required items are outstanding:

- Application Form – Please remove all layers and flatten documents.
- Fire Alarm Plans – Please provide updated plans to reflect code NFPA 2019. Current plans reference NFPA 2016
- Fire Alarm Device Cut Sheets/Submittal Documents - Please remove all layers and flatten documents

The above information must be received by our office to deem this application complete. If the required information is not received within 30 days, your application will be canceled.

Should you require further information, please do not hesitate to contact the Permit Center.

Sincerely,

City of Puyallup Permit Center

(253) 864-4165 option 1