



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Dec 05, 2024 **Inspection Result:** **FAILED**

Permit Number: PRCCP20240215

Property Address: 325 TODD RD NW, PUYALLUP, WA 98371;

Contractor: PENNON CONSTRUCTION CO. INC. 9750 3RD AVE NE SEATTLE, WA 98115 Sean Ewing 9750 3rd Ave NE, Ste 250, Pennon Construction Seattle, WA 98115 (206) 430-2537

To construct: THE PROPOSED PROJECT IS FOR A NEW OPERATIONAL TRAINING CENTER. The project is composed of the main OTC building, and Outdoor Training area. It will be used as a vocational school for UTILITY FIRST RESPONDERS AND construction trades.

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Second tv inspection of the sewer mains.

MH 2 to 1

95LF of ponding = 28.35% fail

The camera starts at 7.5' in ponding water.

0-20', 38'-45', 53'-60', 79'-98', 136'-139', 159'-173', 230'-237', 262'-265', 292'-293', 311'-316', 326'-335'.

MH 3 to 2

146LF of ponding = 49.82% fail

Camera starts at 7.5' in ponding

0-9', 23'-28', 36'-39', 45'-53', 63'-67', 79'-83', 92'-95', 102'-117', 123'-133', 136'-138', 149'-161', 165'-169', 184'-201', 206'-218', 222'-229', 235'-239', 248'-260', 270'-280', 288'-293'.

MH 4 to 3

124LF of ponding = 100% fail

There are three areas over a 1/2" - 94.4', 110.3', and 123'.

The camera is traveling too fast at 81.5' to tell if the belly is at a 1/2" (possible fourth belly).



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

MH 5 to 4

No dye in some areas of ponding water this makes it hard to judge the ponding.

125LF of ponding = 66.84% fail.

0'-37', 53'-74', 81'-120', 125'-137', 143'-146', 157'-159', 167'-173', 180'-185'.

MH 6 to 5

No dye in majority of the ponding and the camera is traveling to fast.

112LF of ponding = 60.54% fail.

2'-8', 22'-31', 39'-42', 49'-91', 96'-102', 110'-112', 120'-142', 152'-165', 173'-182'.

From MH 6 to 7 and 7 to 8 previously passed.

MH 9 to 8

camera starts at 7.5'

61LF of ponding = 23.82% fail.

21'-29', 44'-47', 54'-78', 86'-94', 148'-154', 170'-173', 182'-187', 197'-201'.

Corrections:

- 1 Television Inspection Acceptance Criteria:
 1. Any ponding within a pipe shall be less than one-half inch (1/2") in depth.
 2. The total accumulated ponding length, regardless of depth, from manhole to manhole shall be less than ten (10) percent of the total length from manhole to manhole.Any sewer pipe that exceeds either of the above acceptance criteria will be rejected and require repair and/or replacement by the Contractor.

Sincerely,

Jeff Hill

Development Engineering Inspector

Jhill@PuyallupWA.gov

(253) 204-5633