



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Dec 23, 2024                      **Inspection Result:**      **PARTIAL PASS**

**Permit Number:** PRCCP20240215

**Property Address:** 325 TODD RD NW, PUYALLUP, WA 98371;

**Contractor:** PENNON CONSTRUCTION CO. INC. 9750 3RD AVE NE SEATTLE, WA 98115 Sean Ewing 9750 3rd Ave NE, Ste 250, Pennon Construction Seattle, WA 98115 (206) 430-2537

**To construct:** THE PROPOSED PROJECT IS FOR A NEW OPERATIONAL TRAINING CENTER. The project is composed of the main OTC building, and Outdoor Training area. It will be used as a vocational school for UTILITY FIRST RESPONDERS AND construction trades.

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** JH 6:30pm-TCP check at 6:30pm. All of the signs are up and the type 3 barricades are ready to be slid into the roadway. The road was closed at 7pm. Water was shut down at 7:30 pm. The crew removed the existing eco block from behind the 12" blind flange. Drain Pro vac truck excavated from the existing main to the other side of the storm. Pivetta excavated out the new mains blow off and drained the line. Two eco blocks set in the bottom of the hole for vertical blocking.

**Corrections:**

- 1 Television Inspection Acceptance Criteria:
  1. Any ponding within a pipe shall be less than one-half inch (1/2") in depth.
  2. The total accumulated ponding length, regardless of depth, from manhole to manhole shall be less than ten (10) percent of the total length from manhole to manhole.Any sewer pipe that exceeds either of the above acceptance criteria will be rejected and require repair and/or replacement by the Contractor.

Sincerely,



City of Puyallup

---

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

Jeff Hill

Development Engineering Inspector

[Jhill@PuyallupWA.gov](mailto:Jhill@PuyallupWA.gov)

(253) 204-5633