



City of Puyallup

Fire Prevention

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Mark Smith - Smith Fire Systems

1106 54TH AVE EAST

TACOMA, WA 98424

January 14, 2025

Notice of Incomplete Permit Submittal

RE: Application Number PRFA20250057

Dear Mark Smith - Smith Fire Systems,

A permit application has been received by this office on January 14, 2025. The following required items are outstanding:

- Fire Alarm Plans – Please update code cycle to current code NFPA 2019 or IFC 2021

The above information must be received by our office to deem this application complete. If the required information is not received within 90 days, your application will be canceled.

Should you require further information, please do not hesitate to contact the Permit Center.

Sincerely,

City of Puyallup Permit Center

(253) 864-4165 option 1