



3400 188th St SW #461
Lynnwood, WA 98037
Phone: 425-771-1166
Fax: 425-771-4422

FIRE ALARM / EVELER FREEZER EXPANSION
322 VALLEY AVE NW PUYALLUP WA 98371
Permit Application #PRFA20241553

December 12, 2024

Corrections Requested in Black ABSCO Response in **RED**

1. Linear wire and Heat Detectors do not meet requirements for Total Coverage. -ABSCO removed Linear wire Heat Detection and replaced with Beam type Smoke Detection. Honeywell Intelligent Beam Smoke Detector, Model# ABD-RT2F. ABSCO replaced heat detectors in office area with Smoke Detectors.
2. Remove all heat detectors and replace with smokes. -Absco removed all heat detectors and replace with smokes.
3. Remove all Linear wire and replace with smoke detection. - ABSCO removed Linear wire Heat Detection and replaced with Beam type Smoke Detection. Honeywell Intelligent Beam Smoke Detector, Model# ABD-RT2F
4. Above ceiling detection required. -ABSCO added Smoke Detectors with remote test switch and annunciator to above ceiling areas.
5. Smoke detection required in vestibules. -ABSCO added Smoke Detector above and below ceiling in vestibules.
6. RTU's are required to have Smoke Detection for shutdown. -ABSCO added Relay for HVAC Shutdown on general alarm at main HVAC Control Unit. This was after a meeting with HVAC/Refrigeration contractor.
7. The two Fire Riser rooms are not shown on ABSCO's plans. Refer back to approved Building plans. Smoke detection required in both. -ABSCO added both Fire Riser Rooms to update plans, ABSCO added Smoke Detection and Notification (Strobe) to both Riser Rooms.
8. Remote Pump room not shown on plans for water tank. Smoke Detection required. - ABSCO added Smoke Detection and Notification (Strobe) to remote Pump Room.
9. Plans do not match the approved Building plans. Apply all notes above to new plans and resubmit. -ABSCO to Apply all notes/correction to approved Building plans.
10. Absco added smoke detection and notification to 3 roof top penthouses
11. Relocated Fire Alarm Control Panel to hallway due to equipment located at previous location.
12. ABSCO's UL Listing Account # 46233, ABSCO's UL Listing Party ID# 616858

Please feel free to call if you wish to discuss. -
Make it a great day!

Ken Day

Estimating Project Designer
NICET Level IV – Cert. #97083
Office – 425-771-1166
iPhone – 206-356-4603
Ken.day@abscosolutions.com
www.abscosolutions.com