



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Feb 11, 2025 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRCCP20240215

Property Address: 325 TODD RD NW, PUYALLUP, WA 98371;

Contractor: PENNON CONSTRUCTION CO. INC. 9750 3RD AVE NE SEATTLE, WA 98115 Sean Ewing 9750 3rd Ave NE, Ste 250, Pennon Construction Seattle, WA 98115 (206) 430-2537

To construct: THE PROPOSED PROJECT IS FOR A NEW OPERATIONAL TRAINING CENTER. The project is composed of the main OTC building, and Outdoor Training area. It will be used as a vocational school for UTILITY FIRST RESPONDERS AND construction trades.

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: All storm lines running east to west from P7 to the outfall west of 4th have passed all testing requirements. The storm lines from SDCB #31 to P4 and SDCB #21 to P2 are all the storm lines that remain to be tested with in the ROW.

Corrections:

Sincerely,

Jeff Hill
Development Engineering Inspector
Jhill@PuyallupWA.gov
(253) 204-5633