



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Feb 12, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: PRFUP20231696

Property Address:

Contractor: PSE - ASPLUNDH 2711 PACIFIC AVE SE OLYMPIA, WA 98501

To construct: 101139478-POTELCO CREW TO REPLACE POLE @ P01 (567800-155478)
& INSTALL NEW ANCHOR AND DOWN GUYS. ASPLUNDH CREW TO DO
ANY REQUIRED BRUSH CLEARING. SOFT SURFACE DISTURBANCE ONLY.

On this day we have inspected your construction for **Job Start Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: When I arrived at 8:45 am, two K&D flaggers were still setting signs and a lane had already been taken. There was one flagger at the top of the hill on 3rd ST at the intersection of 14th, and there was no one on the other end of the street where it necked down to one lane. Potelco had their equipment in the lane already. The foreman was dismissive, then combative so I called the general foreman. He called for two additional flaggers.

A vactor truck excavated the pit for the pole, the pole was set at the back of walk and an anchor and down guy were installed. The crew moved to another pole on 3rd ST SE.

-Per the contractor, the hospital was notified last week.

CORRECTIONS: Rake out some rock around the pole and anchor, top with 3-4" soil or mulch

Corrections:

Sincerely,

Cheryl Trimble

Development Engineering Inspector



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

CTrimble@PuyallupWA.gov

(253) 290-9834