



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Mar 05, 2025 **Inspection Result:** **FAILED**

Permit Number: PRCTI20241365

Property Address: 719 RIVER RD, Unit: A, PUYALLUP, WA 98371;

Contractor: KAM CONSTRUCTION, INC. 19419 W TAPPS HWY E BONNEY LAKE, WA 98391 (206) 909-3897

To construct: Convert existing 1700 square foot space - K. NAILS SALON, RIVER RD

On this day we have inspected your construction for **Engineering Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: - Please certify the RPBA and get me a copy.

- Please grout the hole through the wall.

Once completed, schedule another Engineering final.

Corrections:

Sincerely,

Jason Little

Development Engineering Inspector



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

JLittle@PuyallupWA.gov

(253) 244-0387