



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Mar 05, 2025 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRCCP20240215

Property Address: 325 TODD RD NW, PUYALLUP, WA 98371;

Contractor: PENNON CONSTRUCTION CO. INC. 9750 3RD AVE NE SEATTLE, WA 98115 Sean Ewing 9750 3rd Ave NE, Ste 250, Pennon Construction Seattle, WA 98115 (206) 430-2537

To construct: THE PROPOSED PROJECT IS FOR A NEW OPERATIONAL TRAINING CENTER. The project is composed of the main OTC building, and Outdoor Training area. It will be used as a vocational school for UTILITY FIRST RESPONDERS AND construction trades.

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Onsite storm TV testing.

SDCB 1A to 25

Ponding the length of the run. There is trash stuck on the testing ball and water above the outlet I.E. Catch basins and pipe shall be cleaned before the TV inspection.

SDCB 4 to 3

Pass

SDCB 3 to B10

Pass

SDCB 5 to 4

Pass

SDCB 5 to 6

Ponding very close to 0.5". Total ponding 60.52%

Fail.



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

SDCB 6 to 7

Passed

SDCB 6 to 8

42.85% ponding

Fail

SDCB 8 to 9

Pass

SDCB 10 to 11

Pass

SDCB 10 to 3

Pass

SDCB 11 to 12

Pass

SDCB 12 to 13

Pass

SDCB 21 to P2

Pass

SDCB 21 to SDCO 18

59.75 % ponding

1/2" bellies: 0', 85', 98', 137', 179', and 224' to 239'

Fail

SDCB 23 to outfall 1

pass

SDCB 23 to outfall 2

Pass

SDCB 22 to 23

The run is under the 0.5% standard and the 10% ponding standard will not apply.

1/2" or greater bellies: 37', 72', 128', and 119' to 207'.

Fail

SDCB 24 to 25



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

The run is under the 0.5% standard and the 10% ponding standard will not apply.
Pass

SDCB 24 to B9

The run is under the 0.5% standard and the 10% ponding standard will not apply.
1/2" or greater bellies: 37'

Fail

SDCB 25 to outfall

The run is under the 0.5% standard and the 10% ponding standard will not apply.
1/2" or greater bellies: 71'

There are multiple spots just shy of a 1/2" The camera should be ran up hill.

Fail

SDCB 31 to P4

Pass

SDCB 21 to 22

The run is under the 0.5% standard and the 10% ponding standard will not apply.

Pass

Corrections:

Sincerely,

Jeff Hill

Development Engineering Inspector

Jhill@PuyallupWA.gov

(253) 204-5633