



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Mar 21, 2025                      **Inspection Result:**      **PARTIAL PASS**

**Permit Number:** PRCCP20240215

**Property Address:** 325 TODD RD NW, PUYALLUP, WA 98371;

**Contractor:** PENNON CONSTRUCTION CO. INC. 9750 3RD AVE NE SEATTLE, WA 98115 Sean Ewing 9750 3rd Ave NE, Ste 250, Pennon Construction Seattle, WA 98115 (206) 430-2537

**To construct:** THE PROPOSED PROJECT IS FOR A NEW OPERATIONAL TRAINING CENTER. The project is composed of the main OTC building, and Outdoor Training area. It will be used as a vocational school for UTILITY FIRST RESPONDERS AND construction trades.

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** Tv inspection of the sewer line from SSMH 3 to 4 has no ponding water 1/2" or grater. With the AMR PRAMR20250344 being approved the 10% ponding standard shall be waved with the condition that a PCR for the step system be installed. ALL PONDING 1/2" OR ABOVE has been fixed in all of the offsite sewer.

ALL OF THE STORM SYSTEM ONSITE AND OFFSITE HAS PASSED TESTING STANDARDS.

**Corrections:**

Sincerely,

Jeff Hill  
Development Engineering Inspector  
Jhill@PuyallupWA.gov  
(253) 204-5633



City of Puyallup

---

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)