



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Apr 04, 2025                      **Inspection Result:**     **FAILED**

**Permit Number:** PRCCP20240215

**Property Address:** 325 TODD RD NW, PUYALLUP, WA 98371;

**Contractor:** PENNON CONSTRUCTION CO. INC. 9750 3RD AVE NE SEATTLE, WA 98115 Sean Ewing 9750 3rd Ave NE, Ste 250, Pennon Construction Seattle, WA 98115 (206) 430-2537

**To construct:** THE PROPOSED PROJECT IS FOR A NEW OPERATIONAL TRAINING CENTER. The project is composed of the main OTC building, and Outdoor Training area. It will be used as a vocational school for UTILITY FIRST RESPONDERS AND construction trades.

On this day we have inspected your construction for **Erosion And Sediment Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** Pivetta is removing the North silt fence to construct the berm. The earthen berm shall be stabilized, covered, or protected from erosion. There are multiple CB's onsite without any inlet protections. There are multiple spots of damaged, down, or buried silt fence around the site.

**Corrections:**

- 1 1- repair all damaged and removed silt fence
- 2- install outlet protection onsite CB's
- 3- Clean up the track out and cold mix in the ROW
- 4- Stabilize soils / cover soils that are not being worked

Sincerely,

Jeff Hill  
Development Engineering Inspector  
Jhill@PuyallupWA.gov



City of Puyallup

---

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

(253) 204-5633