



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: May 27, 2025 **Inspection Result:** **NOT READY**

Permit Number: PRCTI20241789

Property Address: 402 15TH AVE SE, PUYALLUP, WA 98372;

Contractor: SELLEN 227 WESTLAKE AVE N SEATTLE, WA 98109 (206) 682-7770

To construct: Alterations to Kitchen (#176), Evaluation Room (#161) and adjacent hall -
MULTICARE CHILDREN'S THERAPY UNIT, KITCHEN ALTERATIONS

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1 ; provide fire approved prior to building final inspection.

2 ; will come out for final inspection tomorrow with fire inspector for building final as discussed with contractor.

Corrections:

1 1 ; provide city approved plans on-site at time of inspection.

2 ; electrical lockout installed at panel for stove breaker with cover plate installed at outlet until hood exhaust is approved for use per fire and building.

Sincerely,

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org