



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: May 28, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: PRCTI20241789

Property Address: 402 15TH AVE SE, PUYALLUP, WA 98372;

Contractor: SELLEN 227 WESTLAKE AVE N SEATTLE, WA 98109 (206) 682-7770

To construct: Alterations to Kitchen (#176), Evaluation Room (#161) and adjacent hall -
MULTICARE CHILDREN'S THERAPY UNIT, KITCHEN ALTERATIONS

On this day we have inspected your construction for **Fire Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1. Do not use stove.
2. Blank plate installed for stove outlet to avoid use.
3. Lockout on fuse panel to avoid use.
4. TCO approved for 30 days based on items 2 and 3 being out of commission.
5. Provide a code compliant path for fixing hood issue. This should be resubmitted under this permit to obtain approval and a final.

Sincerely,

David Drake
Building Inspector II
DDrake@PuyallupWA.gov
(253) 864-4171



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org