



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: May 28, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: PRCTI20241789

Property Address: 402 15TH AVE SE, PUYALLUP, WA 98372;

Contractor: SELLEN 227 WESTLAKE AVE N SEATTLE, WA 98109 (206) 682-7770

To construct: Alterations to Kitchen (#176), Evaluation Room (#161) and adjacent hall -
MULTICARE CHILDREN'S THERAPY UNIT, KITCHEN ALTERATIONS

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 2 1; electrical lockout installed at panel for stove breaker with cover plate installed at outlet until hood exhaust is approved for use per fire and building.
- 2 ; t.c.o. approved for 30 days from 5/28/2025

Sincerely,

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org