



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Jul 03, 2025

**Inspection Result:** **FAILED**

**Permit Number:** PRDE20250669

**Property Address:** 1200 7TH AVE SE, PUYALLUP, WA 98372;

**Contractor:**

**To construct:** REMOVE AN EXISTING DETACHED DWELLING UNIT: HOUSE,  
DETACHAED GARAGE & (3) TINY SHEDS ~ 1200 7th AVE TOWNHOMES

On this day we have inspected your construction for **Erosion And Sediment Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** unable to final the permit due to the soils not being stabilized and left over debris onsite.

**Corrections:**

- 1 stabilize all disturbed soils and remove debris

Sincerely,

Jeff Hill  
Development Engineering Inspector  
Jhill@PuyallupWA.gov  
(253) 204-5633