



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jul 07, 2025

Inspection Result: **FAILED**

Permit Number: PRCTI20250557

Property Address: 1601 INDUSTRIAL PARK WAY, PUYALLUP, WA 98371;

Contractor: HAWK BUILDING, LLC. 18429 YEW WAY SNOHOMISH, WA 98296 (425) 273-1583

To construct: DEMO EXISTING DEMISING WALL BETWEEN STE 100 & 102; CONSTRUCT NEW DEMISING WALL TO MAKE STE 100 INTO (2) STES; NO MODIFICATION TO BLDG ENVELOPE & EXTERIOR - PROLOGIS

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 complete pins at 24"o.c. at top track as per city approved plans at Demising wall.

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684