



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Jul 08, 2025

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** PRCTI20250557

**Property Address:** 1601 INDUSTRIAL PARK WAY, PUYALLUP, WA 98371;

**Contractor:** HAWK BUILDING, LLC. 18429 YEW WAY SNOHOMISH, WA 98296 (425) 273-1583

**To construct:** DEMO EXISTING DEMISING WALL BETWEEN STE 100 & 102; CONSTRUCT NEW DEMISING WALL TO MAKE STE 100 INTO (2) STES; NO MODIFICATION TO BLDG ENVELOPE & EXTERIOR - PROLOGIS

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** frame correction complete at top track of demising wall.

**Corrections:**

- 1 complete pins at 24"o.c. at top track as per city approved plans at Demising wall.

Sincerely,

Shannon King  
Building Inspector 2  
ShannonK@PuyallupWA.gov  
(253) 840-6684