



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jul 24, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: E-20-0612

Property Address: 3213 WILDWOOD PARK DR, PUYALLUP, WA 98374;

Contractor: PEASE / SONS PO BOX 44100 TACOMA, WA 98444 Brandon Haskins
10601 Waller Rd E Tacoma, WA 98446 (253) 370-6559

To construct: CIVILS ~ FERRUCCI JHS REMODEL & ADDITION**2021 STORM SDC FEES
UPDATED**STOP WORK ORDER removed on 03/29/2023 by username
'Jeff Hill'.

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: TV inspection and mandrel results

CB109 to SF 4- Pass

CB112 to SF 4- Pass

CB 104 to 115- Pass

CB 107 to 113- Pass

CB 115 to 114- 5/8" belly at 74.9' Once belly is fixed all testing required again

CB 104 to SF4 Pass

Corrections:

Sincerely,

Jeff Hill

Development Engineering Inspector

Jhill@PuyallupWA.gov

(253) 204-5633