



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jul 29, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: E-20-0612

Property Address: 3213 WILDWOOD PARK DR, PUYALLUP, WA 98374;

Contractor: PEASE / SONS PO BOX 44100 TACOMA, WA 98444 Brandon Haskins
10601 Waller Rd E Tacoma, WA 98446 (253) 370-6559

To construct: CIVILS ~ FERRUCCI JHS REMODEL & ADDITION**2021 STORM SDC FEES
UPDATED**STOP WORK ORDER removed on 03/29/2023 by username
'Jeff Hill'.

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Storm pressure testing results.

CB 112 to SF04 failed
CB 109 to 103 passed
CB 103 to 102 passed
CB 102 to 101 passed
CB 202 to 201 passed
CB 202 to 207 passed
CB 202 to 203 passed
CB 203 to 204 passed
SF03 to CB 206 passed

Corrections:

Sincerely,

Jeff Hill
Development Engineering Inspector
Jhill@PuyallupWA.gov



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

(253) 204-5633