



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Aug 20, 2025 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRPF20241230

Property Address: 819 21ST ST SE, PUYALLUP, WA 98372;

Contractor: MOUNTAIN CONSTRUCTION 3411 90TH ST S; SUITE A LAKEWOOD,
WA 98499 (253) 474-5281 Jim Mayer 3411 90th St. S Lakewood, WA
98499 (206) 234-4860

To construct: (6) DOUBLE PORTABLES ~ CCS ELEMENTARY & JR HIGH SCHOOL
PORTABLES LOCATION PROJECT * REVISION (1) - 8/7/2025 -
CONSOLIDATE EOR FOR FOUNDATION PLAN

On this day we have inspected your construction for **Manufactured Or Modular Structure Setup** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: set up complete at units - 2,4,6, pending as built engineering as discussed with contractor.

Corrections:

- 1 ; complete 3 straps and anchor at north and south sides missing at time of inspection.

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

(253) 840-6684