



Plan Change Request

A plan change request is necessary for civil projects that propose substantial changes to the approved civil plans and requires additional review by City of Puyallup review staff. This application should be filled out completely and sent directly to the City Review Engineer assigned to the civil permit application via email.

Project Information

Site Address/ Parcel #: 1200 7th Ave SE Permit #: PRCCP20241694

Owner: SEATAC ENTERPRISE LLC Email: seatacllc@icloud.com

Design Engineer: CES NW Inc Email: dsmith@cesnwinc.com

Contractor: SEATAC ENTERPRISE LLC Email: seatacllc@icloud.com

Originator of the Request: Owner Design Engineer Contractor City of Puyallup

- Does this request require a deviation from city standards? Yes No
- If yes, submit an [Alternative Method's Request](#) via the [CityView Portal](#) instead of this form

➤ Indicate the development infrastructure being affected

Road Storm Water Sanitary Grading Erosion Control

➤ Specify the approved civil plans affected: Sheet C1, C4, C5, C8A and C8B

➤ Describe the change(s) being requested:
The detention pipe is changed to StormTech MC-3500 chamber system. The parking lot grading has been revised to provide the minimum cover.

➤ All signatures are required to process this request unless initiated by the City of Puyallup. Final approval/denial will be made by the City Review Engineer. All changes must be fully approved/denied prior to any work on the requested changes. Any work completed prior to approval is at the risk of the developer/contractor and may not be approved by the City.

Owner
 Jeff Hill Digitally signed by Jeff Hill

 City Inspector

Design Engineer
 Sam Newman

 City Reviewer

Contractor
 Approved

 Approved/ Denied

Date: 7/31/25