

City of Puyallup Development & Permitting Services ISSUED PERMIT	
Building	Planning
Engineering	Public Works
Fire	Traffic

SPRINX

FIRE PROTECTION

EST. 1999

2709 Jahn Ave NW, Suite H2, Gig Harbor WA 98335

Ph. (253) 853-7780 - www.SprinxFire.com

Hydraulic Calculations

Expires
DEC 31, 25

WASHINGTON STATE
CERTIFICATE OF COMPETENCY
FIRE SPRINKLER SYSTEMS

Joseph G. Faulkner
9491-0699-CEG Level 3
Sprinx Fire Protection, Inc.
SPRINFP011LS

Joseph G. Faulkner 08/25/2025
Signature Date

SPRINX FIRE PROTECTION INC.
2709 JAHN AVE NW SUITE H2
GIG HARBOR, WA 98335
253-853-7780

Job Name : ETC Building A Area 1
Drawing : FP-3.0
Location : 2902 E PIONEER PUYALLUP, WA 98372
Remote Area : RA#1
Contract : 24-093CM
Data File : ETC Building A Area 1.WXF

HYDRAULIC CALCULATIONS
for

JOB NAME East Town Crossing Building A
Location 2902 E PIONEER PUYALLUP, WA 98372
Drawing # FP-3.0
Contract # 24-093CM
Date 8/20/2025

DESIGN

Remote area # RA#1
Remote area location UNIT 301 - LIVING ROOM
Occupancy classification RESIDENTIAL NFPA 13R
Density 0.05 - Gpm/SqFt
Area of application 256 - SqFt
Coverage/sprinkler 256 16'X16' - SqFt
Type of sprinkler calculated VIKING VK468 RESIDENTIAL PENDENT K=4.9
Sprinklers calculated 4
In-rack demand N/A - GPM
Hose streams N/A - GPM
Total water required (including hose streams) 53.8947 - GPM @ 32.0799 - Psi
Type of system WET-CPVC
Volume of system (dry or pre-action) N/A - Gal

WATER SUPPLY INFORMATION

Test date 4/16/2024
Location 2902 E PIONEER
Source of info CITY OF PUYALLUP WATER DIVISON

CONTRACTOR INFO SPRINX FIRE PROTECTION
Address 2709 JAHN AVE. / SUITE H2 / GIG HARBOR
Phone # 253-853-7780
Name of designer ALEXANDER J PARADIS
Authority having jurisdiction CITY OF PUYALLUP

NOTES:


Water Supply Curve

SPRINX FIRE PROTECTION INC.
ETC Building A Area 1

Page 2
Date 8/20/2025

City Water Supply:
C1 - Static Pressure : 40
C2 - Residual Pressure: 25
C2 - Residual Flow : 1560


Demand:
D1 - Elevation : 12.776
D2 - System Flow : 53.895
D2 - System Pressure : 32.080
Hose (Demand) : _____
D3 - System Demand : 53.895
Safety Margin : 7.890



Flow Diagram

SPRINX FIRE PROTECTION INC.
ETC Building A Area 1

Page 3
Date 8/20/2025



Fittings Used Summary

SPRINX FIRE PROTECTION INC.
ETC Building A Area 1

Page 4
Date 8/20/2025

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
N *	CPVC 90'El Harvel-Spears		7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O *	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
R *	CPVC Coupling Tee - Run	1	1	1	1	1	1	2	2	0	0	0	0	0	0	0	0	0	0	0	0
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Ziw	Wilkins 350AST	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Flow Summary - NFPA

SPRINX FIRE PROTECTION INC.
ETC Building A Area 1

Page 5
Date 8/20/2025

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TEST	40.0	25	1560.0	39.97	53.89	32.08

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>		<i>Notes</i>
1	106.5	4.9	7.04	13.0	0.05	256
2	107.0		7.05			
3	107.0		7.41			
4	107.0		7.73			
5	107.0		7.92			
6	107.0		8.16			
7	107.0		8.38			
UP6	107.0		8.99			
UP5	96.75		13.69			
UP4	86.5		18.26			
8	86.5		19.05			
TOR	86.5		20.93			
BOR	80.0		24.47			
BKV	77.0		32.07			
WM1	77.0		32.08			
WM2	77.0		32.08			
TEST	77.0		32.08			
9	105.5	4.9	7.7	13.6	0.05	256
10	107.0		7.3			
11	106.5	4.9	7.61	13.52	0.05	256
12	107.0		7.61			
13	106.5	4.9	7.91	13.78	0.05	256
14	107.0		7.95			
UP2	96.75		14.41			
UP1	86.5		18.98			

Final Calculations : Hazen-Williams

SPRINX FIRE PROTECTION INC.
ETC Building A Area 1

Page 6
Date 8/20/2025

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
1 to 2	106.500 107	4.90	13.00 13.0	1 1.101	N	7.0	0.500 7.000 7.500	150 0.0307	7.040 -0.217 0.230		Vel = 4.38	
2 to 3	107 107		0.0 13.0	1 1.101	O	5.0	6.580 5.000 11.580	150 0.0307	7.053 0.0 0.356		Vel = 4.38	
3 to 4	107 107		0.0 13.0	1 1.101	2R	2.0	8.580 2.000 10.580	150 0.0306	7.409 0.0 0.324		Vel = 4.38	
4 to 5	107 107		13.60 26.6	1.25 1.394	R	1.0	4.170 1.000 5.170	150 0.0366	7.733 0.0 0.189		Vel = 5.59	
5 to 6	107 107		13.52 40.12	1.25 1.394	R	1.0	2.080 1.000 3.080	150 0.0782	7.922 0.0 0.241		Vel = 8.43	
6 to 7	107 107		13.77 53.89	2 2.003	2R	2.0	7.250 2.000 9.250	150 0.0230	8.163 0.0 0.213		Vel = 5.49	
7 to UP6	107 107		0.0 53.89	2 2.003	2N	22.0	4.500 22.000 26.500	150 0.0231	8.376 0.0 0.612		Vel = 5.49	
UP6 to UP5	107 96.750		0.0 53.89	2 2.003	R	1.0	10.250 1.000 11.250	150 0.0232	8.988 4.439 0.261		Vel = 5.49	
UP5 to UP4	96.750 86.500		-26.35 27.54	2 2.003	O	10.0	10.250 10.000 20.250	150 0.0067	13.688 4.439 0.135		Vel = 2.80	
UP4 to 8	86.500 86.500		0.0 27.54	2 2.003	2N 14R O	22.0 14.0 10.0	71.580 46.000 117.580	150 0.0067	18.262 0.0 0.784		Vel = 2.80	
8 to TOR	86.500 86.500		26.35 53.89	2 2.003	6R O 3N	6.0 10.0 33.0	32.670 49.000 81.670	150 0.0231	19.046 0.0 1.886		Vel = 5.49	
TOR to BOR	86.500 80		0.0 53.89	2 2.203	B S	8.183 15.003	9.500 23.186 32.686	120 0.0220	20.932 2.815 0.718		Vel = 4.54	
BOR to BKV	80 77		0.0 53.89	6 6.16	T 3E Ziw	43.037 60.252 0.0	75.000 103.289 178.289	140 0.0001	24.465 7.581 0.020		** Fixed Loss = 6.281 Vel = 0.58	
BKV to WM1	77 77		0.0 53.89	6 6.16	T G	43.037 4.304	55.000 47.341 102.341	140 0.0001	32.066 0.0 0.011		Vel = 0.58	
WM1 to WM2	77 77		0.0 53.89	8 8.27	T	55.354	35.000 55.354 90.354	140 0	32.077 0.0 0.002		Vel = 0.32	
WM2 to TEST	77 77		0.0 53.89	8 8.27			25.000 25.000	140 0	32.079 0.0 0.001		Vel = 0.32	

Final Calculations : Hazen-Williams

SPRINX FIRE PROTECTION INC.
ETC Building A Area 1

Page 7
Date 8/20/2025

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
			0.0 53.89						32.080		K Factor = 9.51	
9 to 10	105.500 107	4.90	13.60	1	N	7.0	0.500 7.000 7.500	150	7.700 -0.650 0.250		Vel = 4.58	
10 to 4	107 107		0.0	1	2O	10.0	3.000 10.000 13.000	150	7.300 0.0 0.433		Vel = 4.58	
			0.0 13.60						7.733		K Factor = 4.89	
11 to 12	106.500 107	4.90	13.52	1	O	5.0	1.500 5.000 6.500	150	7.611 -0.217 0.215		Vel = 4.56	
12 to 5	107 107		0.0	1	O	5.0	4.500 5.000 9.500	150	7.609 0.0 0.313		Vel = 4.56	
			0.0 13.52						7.922		K Factor = 4.80	
13 to 14	106.500 107	4.90	13.78	1	N	7.0	0.500 7.000 7.500	150	7.907 -0.217 0.257		Vel = 4.64	
14 to 6	107 107		0.0	1	O	5.0	1.330 5.000 6.330	150	7.947 0.0 0.216		Vel = 4.64	
			0.0 13.78						8.163		K Factor = 4.82	
UP5 to UP2	96.750 96.750		26.36	2	2N 14R	22.0 14.0	71.580 46.000 117.580	150	13.688 0.0 0.723		Vel = 2.68	
UP2 to UP1	96.750 86.500		0.0	2	N	11.0	10.250 11.000 21.250	150	14.411 4.439 0.130		Vel = 2.68	
UP1 to 8	86.500 86.500		0.0	2	O	10.0	0.670 10.000 10.670	150	18.980 0.0 0.066		Vel = 2.68	
			0.0 26.36						19.046		K Factor = 6.04	

SPRINX


FIRE PROTECTION

EST. 1999

2709 Jahn Ave NW, Suite H2, Gig Harbor WA 98335

Ph. (253) 853-7780- www.SprinxFire.com

Hydraulic Calculations

 Expires DEC 31, 25	WASHINGTON STATE CERTIFICATE OF COMPETENCY FIRE SPRINKLER SYSTEMS
Joseph G. Faulkner 9491-0699-CEG Level 3 Sprinx Fire Protection, Inc. SPRINF011LS	
<i>Joseph P. Faulkner</i> Signature	08/25/2025 Date

SPRINX FIRE PROTECTION INC.
2709 JAHN AVE NW SUITE H2
GIG HARBOR, WA 98335
253-853-7780

Job Name : ETC Building A Area 2
Drawing : FP-3.0
Location : 2902 E PIONEER PUYALLUP, WA 98372
Remote Area : RA#2
Contract : 24-093CM
Data File : ETC Building A Area 2.WXF

HYDRAULIC CALCULATIONS
for

JOB NAME East Town Crossing Building A
Location 2902 E PIONEER PUYALLUP, WA 98372
Drawing # FP-3.0
Contract # 24-093CM
Date 8/20/2025

DESIGN

Remote area # RA#2
Remote area location UNIT 301 - BEDROOM
Occupancy classification RESIDENTIAL NFPA 13R
Density 0.05 - Gpm/SqFt
Area of application 324 - SqFt
Coverage/sprinkler 324 18'X18 - SqFt
Type of sprinkler calculated VIKING VK468 RESIDENTIAL PENDENT K=4.9
Sprinklers calculated 1
In-rack demand N/A - GPM
Hose streams N/A - GPM
Total water required (including hose streams) 17.0024 - GPM @ 33.7653 - Psi
Type of system WET-CPVC
Volume of system (dry or pre-action) N/A - Gal

WATER SUPPLY INFORMATION

Test date 4/16/2024
Location 2902 E PIONEER
Source of info CITY OF PUYALLUP WATER DIVISON

CONTRACTOR INFO SPRINX FIRE PROTECTION
Address 2709 JAHN AVE. / SUITE H2 / GIG HARBOR
Phone # 253-853-7780
Name of designer ALEXANDER J PARADIS
Authority having jurisdiction CITY OF PUYALLUP
NOTES:

Water Supply Curve

SPRINX FIRE PROTECTION INC.
ETC Building A Area 2


Page 2
Date 8/20/2025

City Water Supply:

C1 - Static Pressure : 40
C2 - Residual Pressure: 25
C2 - Residual Flow : 1560

Demand:

D1 - Elevation : 12.776
D2 - System Flow : 17.002
D2 - System Pressure : 33.765
Hose (Demand) : _____
D3 - System Demand : 17.002
Safety Margin : 6.231



Flow Diagram

SPRINX FIRE PROTECTION INC.
ETC Building A Area 2

Page 3
Date 8/20/2025

17 17 17 17 8.7 17 17 17
16 ← 17 ← 3 ← 4 ← 5 ← 6 ← 7 ← UP6 ← UP5 ← UP4 ← 8 ← TOR ← BOR ← BKV ← WM1 ← WM2 ← TEST
17 17 17 17 8.7 17 17 17

8.3
UP5 ← UP2 ← UP1 7
8.3

Fittings Used Summary

SPRINX FIRE PROTECTION INC.
ETC Building A Area 2

Page 4
Date 8/20/2025

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
N *	CPVC 90'EI Harvel-Spears		7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O *	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
R *	CPVC Coupling Tee - Run	1	1	1	1	1	1	2	2	0	0	0	0	0	0	0	0	0	0	0	0
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Ziw	Wilkins 350AST	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Flow Summary - NFPA

SPRINX FIRE PROTECTION INC.
ETC Building A Area 2

Page 5
Date 8/20/2025

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TEST	40.0	25	1560.0	39.996	17.0	33.765

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
16	106.5	4.9	12.04	17.0	0.05 324
17	107.0		12.2		
3	107.0		12.78		
4	107.0		13.32		
5	107.0		13.4		
6	107.0		13.45		
7	107.0		13.47		
UP6	107.0		13.55		
UP5	96.75		18.02		
UP4	86.5		22.47		
8	86.5		22.57		
TOR	86.5		22.79		
BOR	80.0		25.69		
BKV	77.0		33.76		
WM1	77.0		33.76		
WM2	77.0		33.77		
TEST	77.0		33.77		
UP2	96.75		18.1		
UP1	86.5		22.56		

Final Calculations : Hazen-Williams

SPRINX FIRE PROTECTION INC.
ETC Building A Area 2

Page 6
Date 8/20/2025

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
16 to 17	106.500 107	4.90	17.00	1	N	7.0	0.500 7.000 7.500	150	12.040 -0.217 0.378			
										Vel =	5.73	
17 to 3	107 107		0.0	1	O	5.0	6.580 5.000 11.580	150	12.201 0.0 0.584			
										Vel =	5.73	
3 to 4	107 107		0.0	1	2R	2.0	8.580 2.000 10.580	150	12.785 0.0 0.533			
										Vel =	5.73	
4 to 5	107 107		0.0	1.25	R	1.0	4.170 1.000 5.170	150	13.318 0.0 0.082			
										Vel =	3.57	
5 to 6	107 107		0.0	1.25	R	1.0	2.080 1.000 3.080	150	13.400 0.0 0.050			
										Vel =	3.57	
6 to 7	107 107		0.0	2	2R	2.0	7.250 2.000 9.250	150	13.450 0.0 0.025			
										Vel =	1.73	
7 to UP6	107 107		0.0	2	2N	22.0	4.500 22.000 26.500	150	13.475 0.0 0.072			
										Vel =	1.73	
UP6 to UP5	107 96.750		0.0	2	R	1.0	10.250 1.000 11.250	150	13.547 4.439 0.031			
										Vel =	1.73	
UP5 to UP4	96.750 86.500		-8.31	2	O	10.0	10.250 10.000 20.250	150	18.017 4.439 0.017			
										Vel =	0.88	
UP4 to 8	86.500 86.500		0.0	2	2N 14R	22.0 14.0	71.580 46.000 117.580	150	22.473 0.0 0.092			
										Vel =	0.88	
8 to TOR	86.500 86.500		8.31	2	6R O	6.0 10.0	32.670 49.000 81.670	150	22.565 0.0 0.224			
										Vel =	1.73	
TOR to BOR	86.500 80		0.0	2	B S	8.183 15.003	9.500 23.186 32.686	120	22.789 2.815 0.085			
										Vel =	1.43	
BOR to BKV	80 77		0.0	6	T 3E	43.037 60.252	75.000 103.289 178.289	140	25.689 8.073 0.002		** Fixed Loss = 6.773	
										Vel =	0.18	
BKV to WM1	77 77		0.0	6	T G	43.037 4.304	55.000 47.341 102.341	140	33.764 0.0 0.001			
										Vel =	0.18	
WM1 to WM2	77 77		0.0	8	T	55.354	35.000 55.354 90.354	140	33.765 0.0 0.0			
										Vel =	0.10	
WM2 to TEST	77 77		0.0	8			25.000 25.000	140	33.765 0.0 0.0			
										Vel =	0.10	

Final Calculations : Hazen-Williams

SPRINX FIRE PROTECTION INC.
ETC Building A Area 2

Page 7
Date 8/20/2025

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****	
			0.0										
TEST			17.00						33.765	K Factor = 2.93			
UP5 to UP2	96.750 96.750		8.31	2	2N 14R	22.0 14.0	71.580 46.000	150	18.017 0.0				
			8.31	2.003	O	10.0	117.580	0.0007	0.086	Vel = 0.85			
UP2 to UP1	96.750 86.500		0.0	2	N	11.0	10.250 11.000	150	18.103 4.439				
			8.31	2.003			21.250	0.0008	0.016	Vel = 0.85			
UP1 to 8	86.500 86.500		0.0	2	O	10.0	0.670 10.000	150	22.558 0.0				
			8.31	2.003			10.670	0.0007	0.007	Vel = 0.85			
			0.0										
8			8.31						22.565	K Factor = 1.75			

SPRINX


FIRE PROTECTION

EST. 1999

2709 Jahn Ave NW, Suite H2, Gig Harbor WA 98335

Ph. (253) 853-7780- www.SprinxFire.com

Hydraulic Calculations

 Expires DEC 31, 25	WASHINGTON STATE CERTIFICATE OF COMPETENCY FIRE SPRINKLER SYSTEMS
Joseph G. Faulkner 9491-0699-CEG Level 3 Sprinx Fire Protection, Inc. SPRINFP011LS	
<i>Joseph G. Faulkner</i> Signature	08/25/2025 Date

SPRINX FIRE PROTECTION INC.
2709 JAHN AVE NW SUITE H2
GIG HARBOR, WA 98335
253-853-7780

Job Name : ETC Building A Area 3
Drawing : FP-3.0
Location : 2902 E PIONEER PUYALLUP, WA 98372
Remote Area : RA#3
Contract : 24-093CM
Data File : ETC Building A Area 3.WXF

HYDRAULIC CALCULATIONS
for

JOB NAME East Town Crossing Building A
Location 2902 E PIONEER PUYALLUP, WA 98372
Drawing # FP-3.0
Contract # 24-093CM
Date 8/20/2025

DESIGN

Remote area # RA#3
Remote area location STAIRWELL
Occupancy classification LIGHT HAZARD
Density 0.10 - Gpm/SqFt
Area of application 273 - SqFt
Coverage/sprinkler 4 HEADS - SqFt
Type of sprinkler calculated VIKING VK178 QR CHROME DRY HORIZONTAL SIDEWALL
Sprinklers calculated 4
In-rack demand N/A - GPM
Hose streams N/A - GPM
Total water required (including hose streams) 62.99 - GPM @ 33.4712 - Psi
Type of system WET-CPVC
Volume of system (dry or pre-action) N/A - Gal

WATER SUPPLY INFORMATION

Test date 4/16/2024
Location 2902 E PIONEER
Source of info CITY OF PUYALLUP WATER DIVISON

CONTRACTOR INFO SPRINX FIRE PROTECTION
Address 2709 JAHN AVE. / SUITE H2 / GIG HARBOR
Phone # 253-853-7780
Name of designer ALEXANDER J PARADIS
Authority having jurisdiction CITY OF PUYALLUP
NOTES:

Water Supply Curve

SPRINX FIRE PROTECTION INC.
ETC Building A Area 3


Page 2
Date 8/20/2025

City Water Supply:

C1 - Static Pressure : 40
C2 - Residual Pressure: 25
C2 - Residual Flow : 1560

Demand:


D1 - Elevation : 12.993
D2 - System Flow : 62.99
D2 - System Pressure : 33.471
Hose (Demand) : _____
D3 - System Demand : 62.99
Safety Margin : 6.489



Flow Diagram

SPRINX FIRE PROTECTION INC.
ETC Building A Area 3

Page 3
Date 8/20/2025



Fittings Used Summary

SPRINX FIRE PROTECTION INC.
ETC Building A Area 3

Page 4
Date 8/20/2025

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
N *	CPVC 90'EI Harvel-Spears		7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O *	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
R *	CPVC Coupling Tee - Run	1	1	1	1	1	1	2	2	0	0	0	0	0	0	0	0	0	0	0	0
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Ziw	Wilkins 350AST	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Flow Summary - NFPA

SPRINX FIRE PROTECTION INC.
ETC Building A Area 3

Page 5
Date 8/20/2025

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TEST	40.0	25	1560.0	39.96	62.99	33.471

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>		<i>Notes</i>
20	107.0	5.6	7.0	14.82	0.1	140
21	107.0		9.46			
22	107.0		9.52			
23	107.0		9.63			
UP3	107.0		10.1			
UP2	96.75		14.74			
UP1	86.5		19.51			
8	86.5		19.68			
TOR	86.5		22.19			
BOR	80.0		25.97			
BKV	77.0		33.45			
WM1	77.0		33.47			
WM2	77.0		33.47			
TEST	77.0		33.47			
30	107.0	5.6	8.52	16.35	0.1	140
40	107.0	5.6	7.83	15.67	0.1	140
50	107.0	5.6	8.32	16.15	0.1	140
7	107.0		10.22			
UP6	107.0		10.29			
UP5	96.75		14.76			
UP4	86.5		19.27			

Final Calculations : Hazen-Williams

SPRINX FIRE PROTECTION INC.
ETC Building A Area 3

Page 6
Date 8/20/2025

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
20 to 21	107 107	5.60	14.82	1	5N 4R	35.0 4.0	24.000 39.000	150	7.000 0.0			
			14.82	1.101			63.000	0.0391	2.461	Vel =	4.99	
21 to 22	107 107		0.0	1.25	R	1.0	4.170 1.000	150	9.461 0.0			
			14.82	1.394			5.170	0.0124	0.064	Vel =	3.12	
22 to 23	107 107		16.35	2	3R	3.0	9.330 3.000	150	9.525 0.0			
			31.17	2.003			12.330	0.0084	0.103	Vel =	3.17	
23 to UP3	107 107		15.67	2	2N	22.0	4.500 22.000	150	9.628 0.0			
			46.84	2.003			26.500	0.0178	0.472	Vel =	4.77	
UP3 to UP2	107 96.750		0.0	2	R	1.0	10.250 1.000	150	10.100 4.439			
			46.84	2.003			11.250	0.0179	0.201	Vel =	4.77	
UP2 to UP1	96.750 86.500		-3.28	2	N	11.0	10.250 11.000	150	14.740 4.439			
			43.56	2.003			21.250	0.0156	0.331	Vel =	4.44	
UP1 to 8	86.500 86.500		0.0	2	O	10.0	0.670 10.000	150	19.510 0.0			
			43.56	2.003			10.670	0.0156	0.166	Vel =	4.44	
8 to TOR	86.500 86.500		19.43	2	6R O	6.0 10.0	32.670 49.000	150	19.676 0.0			
			62.99	2.003	3N	33.0	81.670	0.0308	2.518	Vel =	6.41	
TOR to BOR	86.500 80		0.0	2	B S	8.183 15.003	9.500 23.186	120	22.194 2.815			
			62.99	2.203			32.686	0.0293	0.957	Vel =	5.30	
BOR to BKV	80 77		0.0	6	T 3E	43.037 60.252	75.000 103.289	140	25.966 7.459		** Fixed Loss = 6.16	
			62.99	6.16	Ziw	0.0	178.289	0.0002	0.027	Vel =	0.68	
BKV to WM1	77 77		0.0	6	T G	43.037 4.304	55.000 47.341	140	33.452 0.0			
			62.99	6.16			102.341	0.0001	0.015	Vel =	0.68	
WM1 to WM2	77 77		0.0	8	T	55.354	35.000 55.354	140	33.467 0.0			
			62.99	8.27			90.354	0	0.003	Vel =	0.38	
WM2 to TEST	77 77		0.0	8			25.000	140	33.470 0.0			
			62.99	8.27			25.000	0	0.001	Vel =	0.38	
TEST			0.0 62.99						33.471	K Factor =	10.89	
30 to 22	107 107	5.60	16.35	1	N	7.0	14.330 7.000	150	8.525 0.0			
			16.35	1.101			21.330	0.0469	1.000	Vel =	5.51	
22			0.0 16.35						9.525	K Factor =	5.30	
40 to 23	107 107	5.60	15.67	1	4N R O	28.0 1.0 5.0	7.500 34.000 41.500	150	7.830 0.0			
			15.67	1.101				0.0433	1.798	Vel =	5.28	

Final Calculations : Hazen-Williams

SPRINX FIRE PROTECTION INC.
ETC Building A Area 3

Page 7
Date 8/20/2025

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
			0.0 15.67						9.628		K Factor = 5.05	
50 to 7	107 107	5.60	16.15	1	4N R O	28.0 1.0 5.0	7.500 34.000 41.500	150	8.320 0.0 1.902		Vel = 5.44	
7 to UP6	107 107		0.0 16.15	2	2N	22.0	4.500 22.000 26.500	150	10.222 0.0 0.066		Vel = 1.64	
UP6 to UP5	107 96.750		0.0 16.15	2	R O	1.0 10.0	10.250 1.000 11.250	150	10.288 4.439 0.028		Vel = 1.64	
UP5 to UP4	96.750 86.500		3.28 19.43	2	O	10.0	10.250 10.000 20.250	150	14.755 4.439 0.071		Vel = 1.98	
UP4 to 8	86.500 86.500		0.0 19.43	2	2N 14R O	22.0 14.0 10.0	71.580 46.000 117.580	150	19.265 0.0 0.411		Vel = 1.98	
8			0.0 19.43						19.676		K Factor = 4.38	
UP5 to UP2	96.750 96.750		-3.27 -3.27	2	2N 14R O	22.0 14.0 10.0	71.580 46.000 117.580	150	14.755 0.0 -0.015		Vel = 0.33	
UP2			0.0 -3.27						14.740		K Factor = -0.85	



MEMORANDUM

TO: BRIAN JOHNSON, WATER SYSTEM
SPECIALIST
FROM: KERRI SIDEBOTTOM, P.E.
DATE: APRIL 16, 2024
SUBJECT: EAST TOWN CROSSING ADDITIONAL
FIRE FLOW AVAILABILITY
CITY OF PUYALLUP, PIERCE COUNTY,
WASHINGTON
G&O #21415.19

Per your request, I have analyzed the available fire flow at the proposed East Town Crossing development, in the central part of the City's water service area. Fire flow at this location was previously analyzed in a memo from Gray & Osborne, dated February 14, 2024. The Developer has proposed a Revised Water Piping Plan for the site, which has been analyzed in this memo. The setup of the hydraulic model and the assumptions used to determine the static pressure and available fire flow are noted as follows.

- The available fire flows and pressures are measured at 14 nodes, corresponding to the proposed hydrants within the development, as shown in the attached figure.
- Water system demands are based on projected 2038 demands and reservoirs are depleted of fire suppression and equalizing storage, as established in the *2019 Water System Plan (WSP)*, approved by the Department of Health (DOH). The City's water model was updated in 2021 to reflect additional system improvements since the WSP was developed.
- All pump stations are idle, and the Salmon Springs source is operating at 1,100 gallons per minute (gpm).

The development is located in Zone 1, which is supplied by Maplewood Springs and the 15th Avenue SE Reservoirs. The system was modeled as-is, with the proposed piping indicated on the attached figure. The model was run for two different scenarios, all of which include new 8-inch piping. The new piping for Scenario 1 includes the Phase 1 piping shown on the attached figure in pink. Scenario 2 includes additional piping for Phase 2 of the development is shown in orange on the attached figure.



The available pressure under 2038 peak hour demands at the hydrants is included in Table 1.

TABLE 1

Peak Hour Pressure

Node	Hydrant	Elevation, feet	Peak Hour Pressure, psi
J2238	J	71	41
J2240	L	72	41
J2242	M	72	40
J2244	N	76	39
J2246	H	76	39
J2248	I	76	41
J2250	F	73	40
J2252	D	69	42
J2254	C	67	43
J2256	B	66	43
J2258	A	66	43
J2260	E	72	41
J2274	G	75	39
J2276	K	71	41

The peak hour pressures within the development are essentially the same under either of the proposed scenarios, and the looping does not appreciably impact the pressures.

SCENARIO 1

Scenario 1 includes the piping planned for Phase 1, shown in pink on the attached figure. The piping includes 8-inch mains, mostly dead-ends, extending from the existing 8-inch main running from north to south through the site, as well as a connection to the 16-inch main on Shaw Road, to the west. Part of the existing 8-inch main will be replaced during construction of the development.

Available fire flow was modeled at 12 of the proposed hydrants in the development; Hydrants A through L. The hydrants are located on 8-inch pipes throughout the development, many of which are dead-ends. The results of this modeling are included in Table 2. The modeled fire flow is available at any hydrant individually, but not simultaneously.



TABLE 2
Modeled Fire Flow Availability, Scenario 1

Node	Hydrant	Available Fire Flow, gpm	Residual Pressure at Available Fire Flow, psi	Minimum System Pressure at Available Fire Flow, psi
J2238	J	2,140 ⁽¹⁾	25	25
J2240	L	1,560 ⁽¹⁾	23	23
J2246	H	1,560 ⁽¹⁾	22	22
J2248	I	2,580 ⁽¹⁾	23	23
J2250	F	1,560 ⁽¹⁾	25	25
J2252	D	2,170 ⁽¹⁾	28	28
J2254	C	1,920 ⁽¹⁾	29	28
J2256	B	2,230 ⁽¹⁾	26	26
J2258	A	1,560 ⁽¹⁾	28	28
J2260	E	1,560 ⁽¹⁾	23	23
J2274	G	1,560 ⁽¹⁾	25	25
J2276	K	1,560 ⁽¹⁾	27	27

(1) Limited by maximum system-wide velocity of 10 feet per second.

Fire flow to all of the hydrants is limited by the 10-fps maximum velocity through the existing and proposed 8-inch pipes in this scenario.

SCENARIO 2

Scenario 2 includes the piping indicated for Phases 1 and 2, shown in pink and orange on the attached figure. The piping includes 8-inch pipes extending from the existing 8-inch main running from north to south through the site, a connection to the existing 16-inch main on Shaw Road to the west, and improved looping as compared with Scenario 1.

Available fire flow was measured at the 14 proposed hydrants in the development; Hydrants A through N. The hydrants are located on 8-inch pipes throughout the development. The results of this modeling are included in Table. The modeled fire flow is available at any hydrant individually, but not simultaneously.



TABLE 3
Modeled Fire Flow Availability, Scenario 2

Node	Hydrant	Available Fire Flow, gpm	Residual Pressure at Available Fire Flow, psi	Minimum System Pressure at Available Fire Flow, psi
J2238	J	2,430 ⁽¹⁾	25	25
J2240	L	2,340 ⁽¹⁾	21	21
J2242	M	2,320 ⁽²⁾	20	20
J2244	N	2,120 ⁽²⁾	20	20
J2246	H	2,330 ⁽¹⁾	20	20
J2248	I	2,540 ⁽¹⁾	24	24
J2250	F	1,560 ⁽¹⁾	26	26
J2252	D	2,230 ⁽¹⁾	28	28
J2254	C	1,980 ⁽¹⁾	29	28
J2256	B	2,340 ⁽¹⁾	26	26
J2258	A	1,560 ⁽¹⁾	38	38
J2260	E	1,560 ⁽¹⁾	23	23
J2274	G	1,980 ⁽¹⁾	25	25
J2276	K	2,040 ⁽¹⁾	25	25

(1) Limited by maximum system-wide velocity of 10 fps.

(2) Limited by minimum system-wide pressure of 20 psi at all service locations.

Fire flow to the hydrants is limited by the 10-fps maximum velocity through the existing and proposed 8-inch pipes.

It should be noted that the dead-end 8-inch mains within the proposed site can only provide 1,560 gpm, due to the City's 10-fps velocity limitation considered for the fire flow analysis. Therefore, if 1,500 gpm is required at the hydrant, located on a dead-end main, there is essentially no additional flow available for the sprinkler system supplied by the same dead-end main. This impacts Hydrants A, E, and F in both scenarios, and additionally Hydrants G and H in Scenario 1 only.

The Department of Health and City Standards for water distribution systems are to meet the peak hourly demand of the system while providing a minimum pressure of 30 psi, system-wide. Under peak daily demand with a fire flow, the system is designed to maintain a minimum pressure of 20 psi, system-wide. Although the peak hourly demand pressure may currently be higher than these standards, the Developer must recognize that




April 16, 2024
Page 5

the City may not provide pressure higher than 30 psi in the future. The flows and pressures determined in this memo are based on the approximate hydrant elevation at ground level. The Developer may design their sprinkler system for whatever pressure they wish, however they must recognize and be responsible for conditions when the pressure may be less than currently exists.

KS/sr

0 50 100 150 200 FEET



THE MAP FEATURES ARE APPROXIMATE AND ARE INTENDED ONLY TO PROVIDE AN INDICATION OF SAID FEATURE. THIS IS NOT A SURVEY. THE CITY ASSUMES NO LIABILITY FOR VARIATIONS ASCERTAINED BY ACTUAL SURVEY. ALL DATA IS EXPRESSLY PROVIDED 'AS IS' AND 'WITH ALL FAULTS'. THE CITY MAKES NO WARRANTY OF FITNESS FOR A PARTICULAR PURPOSE.



CITY OF PUYALLUP
PUBLIC WORKS
WATER DIVISION

HYDRAULIC MODEL FOR EAST TOWN CROSSING

SCALE AS SHOWN

04/10/2024

COP/PW/WATER/S_MAINT/PDF/QSEC/
PG104/MODEL EAST TOWN CROSSING