



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Sep 09, 2025 **Inspection Result:** **FAILED**

Permit Number: PRCTI20241789

Property Address: 402 15TH AVE SE, PUYALLUP, WA 98372;

Contractor: SELLEN 227 WESTLAKE AVE N SEATTLE, WA 98109 (206) 682-7770

To construct: Alterations to Kitchen (#176), Evaluation Room (#161) and adjacent hall -
MULTICARE CHILDREN'S THERAPY UNIT, KITCHEN ALTERATIONS

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1; electrical lockout installed at panel for stove breaker with cover plate installed at outlet until hood exhaust is approved for use per fire and building.
- 2 ; t.c.o. approved for 30 days from 5/28/2025
- 2 1. Provide fire final before scheduling building final.

Sincerely,

James LaVergne

JLaVergne@PuyallupWA.gov

(253) 841-5590