



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Oct 29, 2025                      **Inspection Result:**     **NOT READY**

**Permit Number:** PRCTI20250103

**Property Address:** 2511 INTER AVE, PUYALLUP, WA 98372;

**Contractor:** MOUNTAIN CONSTRUCTION 3411 90TH ST S; SUITE A LAKEWOOD,  
WA 98499 (253) 474-5281

**To construct:** Remodel of this warehouse was accomplished before being approved by the City of Puyallup. A full review and inspection must be accomplished by the City of Puyallup. What must be added is a full sprinkler system for the warehouse, office area and mezzanine. All restrooms must be brought up to code. The parts area must be brought up to structural compliance.

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** Final fire approval then building final.

**Corrections:**

- 1 1. Fire final scheduled for 10-27-25 at 3 pm.
2. Paint accessible rout from city sidewalk to entry gate.
3. Provide 44" clearance at front railing accessible path.
4. Provide accessible ADA handle and latch on gate or remove gate.
5. Install new door hardware at Wherehouse shop exit door.

Sincerely,

James LaVergne

JLaVergne@PuyallupWA.gov

(253) 841-5590



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)