



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Oct 31, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: PRCTI20250103

Property Address: 2511 INTER AVE, PUYALLUP, WA 98372;

Contractor: MOUNTAIN CONSTRUCTION 3411 90TH ST S; SUITE A LAKEWOOD,
WA 98499 (253) 474-5281

To construct: Remodel of this warehouse was accomplished before being approved by the City of Puyallup. A full review and inspection must be accomplished by the City of Puyallup. What must be added is a full sprinkler system for the warehouse, office area and mezzanine. All restrooms must be brought up to code. The parts area must be brought up to structural compliance.

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

Sincerely,

James LaVergne

JLaVergne@PuyallupWA.gov

(253) 841-5590