

DIAMOND

CONSTRUCTION

SERVICES LLC

12/7/25

Permit #PRMH20251492

Re: Correction #2 response,

- Please specify how the new gas piping and equipment along the outdoor section will be supported and protected from physical damage.

Updated comment (review #2): The plans state that a section of pipe will cross over a 4ft gap to reach the outdoor MAU. Section 404.9 of the 2021 Washington State Fuel Gas Code states that gas pipes installed outdoors and above ground must be securely supported and located where it will be protected from physical damage. Please detail and/or specify on the plans how this will be accomplished. [Comment Correction; pg. N/A]

- The gas pipe diameter and pipe material was provided; however, the inlet gas pressure, length of run, etc. are required to ensure the pipe size and material are sufficient. Please contact a Mechanical Engineer for assistance if needed. [Comment Correction; pg. N/A]

- Verify whether an overpressure protection device is required. Reference section 416.1 and 416.2 of the 2021 Washington State Fuel Gas Code. [Comment Correction; ; pg. N/A]

All these corrections are addressed on the CORRECTION_#2_PLAN

Sincerely,

Dale Fite

Dale Fite

Diamond Construction Services LLC