



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Dec 16, 2025                      **Inspection Result:**      **PARTIAL PASS**

**Permit Number:** PRMH20251492

**Property Address:** 1601 INDUSTRIAL PARK WAY, PUYALLUP, WA 98371;

**Contractor:** DIAMOND CONSTRUCTION SERVICES 35420 MILITARY RD S AUBURN,  
WA 98001

**To construct:** Connect gas line to new ground mounted make-up air unit. - TRIMLITE  
@ PROLOGIS, STE 101

On this day we have inspected your construction for **Gas Test Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** Pressure test at 10# approved

**Corrections:**

Sincerely,

James LaVergne

JLaVergne@PuyallupWA.gov

(253) 841-5590