



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Dec 29, 2025 **Inspection Result:** **NOT READY**

Permit Number: PRCTI20250697

Property Address: 310 31ST AVE SE, PUYALLUP, WA 98374;

Contractor: E M PRECISION LLC 1407 VALENTINE AVE SE, STE 105 PACIFIC, WA 98047 (253) 268-0742

To construct: INTERIOR ALTERATION: CONVERT VACANT RESTAURANT SPACE TO WIENERSCHNITZEL RESTAURANT. MINOR WALL CHANGES AND NEW CEILING. PROVIDE NEW KITCHEN EQUIPMENT, FIXTURES, FINISHES AND DINING FURNITURE. NO CHANGES TO BUILDING ENVELOPE. - WIENERSCHNITZEL SOUTH HILL

On this day we have inspected your construction for **Exhaust Hood Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1. Have grease duct flowing correct direction per manufacturing arrows.

Corrections:

1. Have grease duct flowing correct direction per manufacturing arrows.

Sincerely,

James LaVergne

JLaVergne@PuyallupWA.gov

(253) 841-5590