



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jan 06, 2026

Inspection Result: PARTIAL PASS

Permit Number: PRCTI20251654

Property Address: 1601 INDUSTRIAL PARK WAY, PUYALLUP, WA 98371;

Contractor: TBD TBD WA

To construct: Temporary Occupancy - We have broken out the floor plan into 2 sections (TCO and CofO). We are attempting to get a TCO for the area where we do not have any equipment so the operations side of the business can continue to operate while we work through the required activities to achieve a CofO for the full space. We have been working with Stan and Julie on a phased approach with this first permit being phase I - TCO and phase II - CofO

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1. Provide toilet flush valves to open side of ADA restrooms or install sensory type.
2. Provide hammer arrestors at all dishwashers, ice machines.
3. Insulate copper main water lines over head.
4. Provide fire final for rest of T/I space.
5. Okay to use racking.

Corrections:

- 1 1. Provide toilet flush valves to open side of ADA restrooms or install sensory type.
2. Provide hammer arrestors at all dishwashers, ice machines.
3. Insulate copper main water lines over head.
4. Provide fire final for rest of T/I space.
5. Okay to use racking.

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

James LaVergne

JLaVergne@PuyallupWA.gov

(253) 841-5590