



**FIRESHIELD**

Phone: 253-851-0030 Fax: 253-851-9782

P.O. BOX 2389 Gig Harbor, WA 98335

[www.fireshieldinc.com](http://www.fireshieldinc.com)

CITY OF PUYALLUP  
333 S MERIDIAN  
PUYALLUP, WA 98371  
ATTN: To whom it may concern

January 23, 2026

RE: Pandora-South Hill Submittal

To whom it may concern,

In regard to the hydraulic calculations for this project. Hydraulic calculations are not required or necessary for the work performed on this project. The sprinkler system at Pandora-South Hill is existing and has been previously hydraulically calculated. We are not changing the sprinkler system in any way that would affect the previously approved hydraulic calculations. There is no change to the existing sprinkler spacing, k-factor, occupancy or pipe routing. Sprinklers are currently installed on flexible sprinkler drops and will only be relocated to new ceiling tile locations as necessary.

Sincerely,

Fireshield, Inc.  
Ian Rogers  
Designer