



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Feb 04, 2026                      **Inspection Result:**      **PARTIAL PASS**

**Permit Number:** PRCTI20250324

**Property Address:** 1015 39TH AVE SE, PUYALLUP, WA 98374;

**Contractor:** JTM CONSTRUCTION 5900 AIRPORT WAY SOUTH, #110 SEATTLE, WA 98108 (206) 773-3360

**To construct:** Commercial tenant improvement to existing 50,767 sf space - COP ~ PUBLIC SAFETY BUILDING \* REVISION (1) - 8/21/2025 - GENERATOR DEFERRED SUBMITTAL \* REVISION (2) - 10/30/2025 - EXTERIOR CANOPY CONNECTIONS

On this day we have inspected your construction for **Ceiling Grid/T-Bar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** 1. Provide engineering approval for spliced 14'+ diagonal brace. Okay to install ceiling tile room A1004. Will spot check at next inspection.

**Corrections:**

1. Provide engineering approval for spliced 14'+ diagonal brace. Okay to install ceiling tile room A1004. Will spot check at next inspection.

Sincerely,



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)



James LaVergne

[JLaVergne@PuyallupWA.gov](mailto:JLaVergne@PuyallupWA.gov)

(253) 841-5590