



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Feb 10, 2026

**Inspection Result:** NOT READY

**Permit Number:** PRCTI20251520

**Property Address:** 1601 INDUSTRIAL PARK WAY, PUYALLUP, WA 98371;

**Contractor:** ADVANCED FINISHING SYSTEMS INC 7515 NE 33RD DR. Portland, OR 97211 (503) 285-0569

**To construct:** Installation of Qty (3) open faced booths, Qty (1) Industrial Paint Mixing room, Qty (1) Industrial drying enclosure, Qty (5) Exhaust Ducts and Qty (1) Make-up air unit and intake ducting. - TRIMLITE @ PROLOGIS STE. 101 & 102

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** 1. Contractor not on site. 8:58am  
2. Provide fire final before building final.  
3. Provide balance reports make up air reports.

**Corrections:**

- 1 1. Contractor not on site. 8:58am
2. Provide fire final before building final.
3. Provide balance reports make up air reports.

Sincerely,



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)



James LaVergne

[JLaVergne@PuyallupWA.gov](mailto:JLaVergne@PuyallupWA.gov)

(253) 841-5590